

Palm Beach County Water Utilities - Eastern Region

Official 2025 provider report - translated for quick property discussions

REPORT STATUS Zero water-quality violations reported

Quick provider-reported results

These are utility-system results, not a laboratory test of an individual home.

SUBSTANCE	PROVIDER RESULT	LIMIT / BENCHMARK
Barium	Up to 0.00614 ppm	2 ppm
Fluoride	Up to 0.898 ppm	4 ppm
Nitrate	Up to 0.037 ppm	10 ppm
Nitrite	Up to 0.030 ppm	1 ppm
Sodium	Up to 49.7 ppm	160 ppm Florida standard
Radium 228	Up to 1.20 pCi/L	5 pCi/L

What this means for a property

Palm Beach County Water Utilities reported separate data for its eastern and western systems. These results apply to the eastern service region, which includes much of unincorporated Palm Beach County, Royal Palm Beach, Greenacres and Haverhill.

IMPORTANT PROPERTY BOUNDARY

Confirm this exact utility on the water bill. These results do not apply to every Palm Beach County address. Service lines, building plumbing, fixtures and water age can change conditions at an individual tap.

Best use: attach to a listing, inspection discussion, HOA update or property-management file after confirming the utility. It is not a certification, inspection or guarantee of water quality at the property.

Full plain-English report: floridatapreport.com/water-report/palm-beach-county-eastern

Official source: https://discover.pbc.gov/waterutilities/PubDoc/CCR_2025.pdf

Prepared August 28, 2026